



Arnold Schwarzenegger
Governor

CLIMATE CHANGE, EXTREME HEAT, AND ELECTRICITY DEMAND IN CALIFORNIA

PIER PROJECT REPORT

Prepared For:
California Energy Commission
Public Interest Energy Research Program

Prepared By:
Lawrence Berkeley National Laboratory
Texas Tech University
University of California, Berkeley



**California Climate Change Center
Report Series Number 2007-007**

Prepared By:

Norman L. Miller and Jiming Jin, Lawrence Berkeley National Laboratory, Berkeley, California

Katharine Hayhoe, Texas Tech University, Lubbock, Texas

Maximilian Auffhammer, University of California, Berkeley

Commission Contract No. 500-99-013

Commission Work Authorization No: 119

Prepared For:

Public Interest Energy Research (PIER) Program

California Energy Commission

Beth Chambers

Contract Manager

Kelly Birkinshaw

Program Area Lead

Energy-Related Environmental Research

Laurie ten Hope

Office Manager

Energy Systems Research

Martha Krebs

Deputy Director

ENERGY RESEARCH & DEVELOPMENT DIVISION

B. B. Blevins

Executive Director

DISCLAIMER

This report was prepared as the result of work sponsored by the California Energy Commission. It does not necessarily represent the views of the Energy Commission, its employees or the State of California. The Energy Commission, the State of California, its employees, contractors and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the uses of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the California Energy Commission nor has the California Energy Commission passed upon the accuracy or adequacy of the information in this report.

Acknowledgments

Support for this work was provided by the California Energy Commission and by the California Environmental Protection Agency as a contribution to the Governor's Climate Science report. The findings of this report do not necessarily represent the views of the funding agencies or the State of California. Work performed for the Department of Energy at Berkeley National Laboratory is under contract DE-AC03-76SF0098.

Please cite this report as follows:

Miller, Norman L., Jiming Jin, Katharine Hayhoe, and Maximilian Auffhammer. 2007. *Climate Change, Extreme Heat, and Energy Demand in California*. California Energy Commission, PIER Energy-Related Environmental Research Program. CEC-500-2007-023.

Preface

The Public Interest Energy Research (PIER) Program supports public interest energy research and development that will help improve the quality of life in California by bringing environmentally safe, affordable, and reliable energy services and products to the marketplace.

The PIER Program, managed by the California Energy Commission (Energy Commission), conducts public interest research, development, and demonstration (RD&D) projects to benefit California's electricity and natural gas ratepayers. The PIER Program strives to conduct the most promising public interest energy research by partnering with RD&D entities, including individuals, businesses, utilities, and public or private research institutions.

PIER funding efforts are focused on the following RD&D program areas:

- Buildings End-Use Energy Efficiency
- Energy-Related Environmental Research
- Energy Systems Integration
- Environmentally Preferred Advanced Generation
- Industrial/Agricultural/Water End-Use Energy Efficiency
- Renewable Energy Technologies
- Transportation

In 2003, the California Energy Commission's Public Interest Energy Research (PIER) Program established the **California Climate Change Center** to document climate change research relevant to the states. This Center is a virtual organization with core research activities at Scripps Institution of Oceanography and the University of California, Berkeley, complemented by efforts at other research institutions. Priority research areas defined in PIER's five-year Climate Change Research Plan are: monitoring, analysis, and modeling of climate; analysis of options to reduce greenhouse gas emissions; assessment of physical impacts and of adaptation strategies; and analysis of the economic consequences of both climate change impacts and the efforts designed to reduce emissions.

The California Climate Change Center Report Series details ongoing Center-sponsored research. As interim project results, the information contained in these reports may change; authors should be contacted for the most recent project results. By providing ready access to this timely research, the Center seeks to inform the public and expand dissemination of climate change information, thereby leveraging collaborative efforts and increasing the benefits of this research to California's citizens, environment, and economy.

Climate Change, Extreme Heat, and Energy Demand in California is the final report for the Assessing Potential Impacts of Climate Change in California project (contract number 500-99-013, work authorization number 119) conducted by Lawrence Berkeley National Laboratory, Texas Tech University, and the University of California, Berkeley.

For more information on the PIER Program, please visit the Energy Commission's website www.energy.ca.gov/pier/ or contact the Energy Commission at (916) 654-5164.

Table of Contents

Preface.....	iii
Abstract	vii
Executive Summary	1
1.0 Introduction.....	5
2.0 Approach.....	9
3.0 Results.....	13
3.1. Projected Increases in T90 Events	13
3.2. Projected Increases in CDD Values.....	15
3.3. Projected Increase in Electricity Demand	17
4.0 Discussion.....	19
5.0 Summary and Conclusions	21
6.0 References.....	23

List of Figures

Figure 1. Projected average summer (JJAS) temperature increases for California under the SRES higher (A1FI), mid-high (A2), and lower (B1) emissions scenarios, as simulated by the HadCM3, GFDL CM2.1, and PCM models. Temperature changes are larger under the higher emission scenarios as compared to the lower, and for the higher sensitivity models (HadCM3 and GFDL CM2.1) as compared to the lower sensitivity model (PCM).....	10
Figure 2. California-wide projected average number of JJAS T90 days per year from 1975 to 2100. Year-to-year variations have been smoothed using a 10-year running mean to show long-term trends. Projected values are shown for the HadCM3, GFDL CM2.1, and PCM models. Shaded arrows indicate the end-of-century range for simulations corresponding to the SRES A1fi (higher, red/orange), A2 (mid-high, blue), and B1 (lower, green) emission scenarios.....	14
Figure 3. California-wide duration and intensity for JJAS T90 events from 1960 to 2100 as simulated by the HadCM3, GFDL and PCM models for the SRES A1fi (higher), A2 (mid-high), and B1 (lower) emission scenarios, as labeled. Note that GFDL A1fi simulations were not available at the time of calculation.....	16
Figure 4. Projected increase in annual CDD for a 65°F (solid) vs. a 75°F (lined) average temperature threshold for 2070–2099, relative to 1961–1990. Results shown are the averaged projections from the HadCM3, GFDL2.1, and PCM models for the SRES A2 (mid-high, orange) and B1 (lower, yellow) emission scenarios for five California cities. Comparison of the projected change based on a higher vs. a lower threshold value for CDD calculation illustrates the adaptation potential for mitigating projected future energy demand, which appears to be greater for coastal cities (San Francisco, Los Angeles) and less for inland areas (Sacramento, Fresno, San Bernardino).....	20

List of Tables

Table 1. T90 threshold values (in degrees Celsius, determined such that an average of 12 days per year exceed the T90 threshold during the period 1961–1990), and projected increased number of days exceeding the 1961–1990 T90 threshold for near-term (2005–2034), mid-century (2035–2064), and end-of-century (2070–2099) periods. Values shown are the range given by HadCM3, GFDL CM2.1, and PCM model simulations for the SRES A1fi (higher), A2 (mid-high), and B1 (lower) emissions scenarios.....	15
Table 2. Historical (1961–1990) simulated and projected future change in annual Cooling Degree Days (CDD) relative to the historical average for five California cities, listed from low to high present-day CDD values. Values shown for the SRES A1fi (higher), A2 (mid-high), and B1 (lower) emission scenarios for the range simulated by downscaled projections from the HadCM3, GFDL2.1, and PCM models	17

Abstract

This study analyzed the relationship among climate change, extreme heat, and electricity demand in California through the use of atmosphere-ocean general circulation models. These model-based projections of temperature over the coming century were forced by three scenarios from the *Intergovernmental Panel on Climate Change Special Report on Emissions Scenarios*. These analyses indicate that extreme heat events in California will increase rapidly, exceeding the rate of increase in mean temperature. *Extreme heat* is defined here by the 90 percent exceedance probability (T90) of the warmest summer days under the current climate. The number of extreme heat days in Los Angeles, where T90 is currently 95°F, may increase from the present-day value of 12 days per year up to 96 days per year by 2100, implying current heat wave conditions may last for the entire summer. Projected increases in extreme heat under the higher A1fi scenario by 2070–2099 tend to be 20–30 percent higher than those projected under the lower B1 scenario. These findings, combined with observed relationships between high temperature and electricity demand for air-conditioning, suggest potential shortfalls in transmission and supply during more frequent future T90 peak electricity demand periods. Electricity response to recent extreme heat events suggests that peak electricity demand will further challenge planned supply capacities when population and income growth are taken into account.

Keywords: California, climate change, extreme heat, electricity demand, heat wave

Executive Summary

Introduction

California is one of the world's largest economies and a world leader in energy efficiency and demand-side management practices. Statewide, electricity demand per capita has remained nearly flat over the last few decades, partly due to energy efficiency incentives. However, California's aggregate energy demand is growing rapidly, spurred by rapid population growth, especially in the warm Central Valley, and an overall increase in air conditioner use.

Over the twenty-first century, the frequency of extreme heat events for major cities in heavily air-conditioned California is projected to increase rapidly and, with it, peak electricity demand for air conditioning. In 2004, for example, 30 percent of California peak electricity demand was attributable to residential and commercial air conditioning use alone. The upward trend in aggregate peak demand in California is expected to approach or exceed 67 gigawatts (GW) in 2016, which is a 1.35 percent per year increase since 2000. The anticipated population growth underlying these forecasts over the same period is 1.30 percent, indicating that demand growth is expected to very slightly outpace population growth. During summertime extreme heat days in California, the use of air conditioning and other cooling appliances increases electricity load near-linearly with higher temperatures.

Purpose

Electricity in California is a resource already under stress. Over the coming century, projected increases in both mean and extreme temperatures are projected to challenge California's electricity supply, particularly during times of peak demand. This assessed the likely magnitude of expected changes, given present-day population and technology.

Project Objective

This study's objective was to quantify the impacts of extreme heat days on peak electricity demand through the use of atmosphere-ocean general circulation models. These model-based projections of temperature over the coming century were forced by three scenarios from the *Intergovernmental Panel on Climate Change Special Report on Emissions Scenarios*: the higher emission scenario (A1fi, fossil intensive, with rapid technological and economic growth); mid-high emission scenario (A2, a heterogeneous world, with regionally oriented development and slower growth), and lower emission scenario (B1, a convergent world that transitions rapidly to an information-based, rather than material-based, economy). To this end, the researchers first calculated the historical 1961–1990 maximum temperature exceedance threshold for the 10 percent warmest June through September (JJAS) days—the defining threshold referred to as T90. The T90 values represent an important metric in California energy capacity analyses and are often described as the 1-in-10 JJAS high temperature days. In addition to the T90 values, the researchers also calculated average JJAS cooling degree days (CDD). Cooling degree day values are a common metric used to estimate the energy requirements for air conditioning, and they are calculated using the equation $CDD = (Ta - Tac)^*days$, where Ta is the daily mean near-

surface air temperature, $T_{ac} = 65^{\circ}\text{F}$ (18°C) is an average daily-mean temperature threshold for human thermal comfort, and $days$ is the number of days with temperatures exceeding T_{ac} .

Project Outcomes

Increases in temperature extremes and variance are projected to exceed the rate of increase in mean temperature due to climate change over the coming century. Furthermore, the degree of change expected depends critically on the emissions pathway followed over that time; that is, the technological, social, and political decisions made over that time frame will affect emissions and their effect on the climate.

Overall, projected increases in extreme heat under the higher A1fi emission scenario by 2070–2099 tend to be 20–30 percent higher than those projected under the lower B1 emission scenario. Increases range from approximately double the historical number of days for inland California cities (such as Sacramento and Fresno) and up to four times present-day levels for previously temperate coastal cities (such as Los Angeles and San Diego), implying that current-day “heat wave” conditions may dominate summer months—and patterns of electricity demand—in the future. When the projected extreme heat and observed relationships between high temperature and electricity demand for California were mapped onto current electricity availability, maintaining technology and population constant for demand-side calculations, researchers found a potential for electricity deficits as high as 17 percent during T90 peak electricity demand periods.

Conclusions

All indicators point to increases in summer electricity demand in California, even when confounding factors such as increased population and market saturation of air conditioning are disregarded. Through calculation of projected increases in extreme heat and electricity demand, this research quantified the difference in potential impacts resulting from lower and higher emissions scenarios. Model uncertainties notwithstanding, extreme heat and associated human health risks and electricity demands under the B1 lower emissions scenario are significantly lower than those projected to occur under the higher A2 and A1fi scenarios. Calculations of electricity demand under a range of human comfort levels also highlight the potential for adaptation to play a major role, reducing projected increases in electricity demand by roughly one third for inland cities, and by as much as 95 percent for cooler coastal cities.

Recommendations

Alternative technologies such as solar photovoltaic electricity generation represent an important future technology for this region, with electricity production being proportional to solar radiation and thus closely matching summer peak electricity demand. Technologies such as these have the potential to reduce the cost associated with increased demand for cooling under a warmer climate without increasing emissions of greenhouse gases that are causing the problem in the first place.

Benefits to California

The influence of climate change on extreme heat and electricity demand in California and other similar air-conditioned regions is likely to challenge current-day electricity providers, spur conservation and adaptation measures, and emphasize the potential for emissions mitigation efforts such as those already adopted by the State of California to reduce projected impacts through following a lower emissions pathway worldwide.

1.0 Introduction

Since 1980, U.S. electricity demand has increased by more than 75%, with the largest increase in residential and commercial sectors for space heating and cooling. As the southwestern United States becomes more populated and extreme heat days become more frequent, electricity demand will continue to rise. A 2005 Government Accountability Office report (GAO 2005) on meeting energy demand in the twenty-first century states that the United States accounts for 5% of the world's population, yet consumes 25% of the annual energy used worldwide. The GAO report concludes that due to consumer choices of high consumption, all major fuel sources face environmental, economic, or other constraints or trade-offs in meeting projected demand. Clear and consistent policy is therefore needed to guide energy markets, suppliers, and consumers.

The nation's energy infrastructure, its refinery capacity, and electricity line transmission system have not adequately kept up with peak demand, and electricity supply shortfalls have resulted. Electricity generation and transmission deregulation have compounded these problems, as remote transmission and energy gaming have pushed electricity flow up to and beyond the capacity limit, often resulting in electricity supply failure. This has already occurred during extreme summer heat events over the last several years, most notably in the summer of 2003, when a system failure resulted in the largest blackout in U.S. history, leaving as many as 50 million people without power for several days.

In addition to increasing electricity demand, significant increases in the frequency, intensity, and duration of summertime extreme heat days are also projected due to climate change (Houghton et al. 2001; Hayhoe et al. 2004; Tebaldi et al. 2006; Miller and Hayhoe 2006; Alley et al. 2007). Extreme heat days are defined here as the 10% warmest days of the summer, calculated as 1961–1990 warmest days exceeding the 90% probability of the summertime daily maximum temperatures (T90) for a given location or region. The correlation between daily mean near-surface air temperature (Ta) and peak electricity demand during such T90 heat extremes suggests the potential for significant temperature-driven increases in future electricity demand for air conditioning (Belzer et al. 1996; Amato et al. 2005; Mendelsohn and Neumann 1999; Rosenthal and Gruenspecht 1995; Henley and Peirson 1998; Cartalis et al. 2001; Valor et al. 2001). Although this would be expected in the heavily air-conditioned South, such increases may also occur in northern cities. For example, Colombo et al. (1999) analyzed the frequency of extreme heat and electricity demand for nine Canadian cities using the current climate and a warmer climate based on a doubling in atmospheric greenhouse gas (GHG) emissions. Their study suggests that a 3°C increase in the daily maximum temperature would lead to a 7% increase in the standard deviation of current peak energy demand during the summer.

California is one of the world's largest economies and a world leader in energy efficiency and demand-side management practices. Statewide, electricity demand per capita has remained essentially flat, partially due to energy efficiency incentives. However, California's aggregate energy demand is growing rapidly, spurred by the rapid expansion of population (over 36 million) especially in the warm Central Valley region, and an overall increase in the use of air conditioners. The upward trend in aggregate peak demand in California is expected to approach or exceed 67 gigawatts (GW) in 2016, which is a 1.35% per year increase since 2000

(CEC 2005). The anticipated population growth underlying these forecasts over the same period is 1.30% (CEC 2005), indicating that demand growth is expected to very slightly outpace population growth. During warm summer T90 days in California, the use of air conditioning and other cooling appliances increases electricity load near-linearly with higher temperatures (CEC 2004; Bartholomew et al. 2002). In 2004, 30% of California peak electricity demand was due to residential and commercial air conditioning use alone (CEC 2004).

Extreme heat days during recent summers have triggered energy alerts with brownouts and blackouts. Electricity transmission lines and related infrastructure, along with the restructured energy market, place limits on current expansion of the flow of electricity supply during peak demand periods and are not expected to be rectified in the near-term (CEC 2004). During the recent July 2006 heat wave, the warmest year to date since California weather records began in 1895 (NOAA 2006), California minimum temperatures were 8°F–15°F (4.4°C–8.3°C) above average. Los Angeles experienced 20 consecutive days at or above 100°F (38°C), and Sacramento experienced 11 consecutive days at or above 110°F (43°C). During this heat wave, there was an all-time single day record electricity demand of 50.3 GW and several regions within California were without power from hours to days due to infrastructure failures (e.g., transformers in Northern California were unable to cool properly and caught fire).

One indicator of increased “peakiness” of the electric system is the load factor, which measures the relationship between annual peak demand in GW and consumption in GW hours. If peak demand grows more quickly than the aggregate consumption, then the load factor decreases, highlighting the likelihood of the types of conditions leading to brownouts or even blackouts. CEC (2005) shows that load factors adjusted for weather have decreased in recent years in California, which is primarily blamed on the increased use of air conditioners.

California's electricity supply reliability problems during periods when demand exceeds the available generating and/or transmitting capacity has already resulted in industries moving to regions with a more dependable supply of electricity. In the future, this issue is likely to continue to plague California, the southwestern United States, and expanding regions where electricity shortfalls occur.

World demand for energy is approximately equivalent to a continuous power consumption of 13 trillion watts (i.e., 13 TW). With aggressive conservation and energy efficiency, an expected global population of 9 billion accompanied by rapid technology growth is projected to more than double energy demand to 30 TW by 2050 and to more than triple to 46 TW by 2099 (GAO 2005). The same Government Accounting Office report (GAO 2005) on meeting energy demand in the twenty-first century concludes that due to the consumer choices of high consumption, all major fuel sources face environmental, economic, or other constraints or trade-offs in meeting projected demand. Energy shortfalls are already occurring in China and other emerging economies, where the economic expansion has led to a surge in the adoption of household appliances, including air conditioners. If our economies continue on a high-energy consumption trajectory into the future, projected temperature increases over the coming century may further strain energy providers, resulting in electricity shortages and negative health and economic impacts.

Section 2 describes the details of this study's approach to determining historical and projected extreme heat frequency, intensity, and duration, cooling degrees days, and electricity demand. This is followed by a discussion of the results, an evaluation of a potential adaptation strategy, and conclusions.

2.0 Approach

To quantify the impacts of extreme heat days on peak electricity demand, the historical 1961–1990 maximum temperature exceedance threshold for the 10% warmest June through September (JJAS) days (averaging approximately 12 days per year over the historical period) is calculated and referred here as $T90$. The number of projected future JJAS days with maximum temperatures at or above the historical $T90$ values are then calculated. $T90$ values are an important metric used in California energy capacity analyses and are often described as the 1-in-10 JJAS high temperature days. In addition to the $T90$ values, JJAS cooling degree days (CDD) are also calculated, defined by the National Climatic Data Center (Owenby et al. 2005) as $CDD = (Ta - Tac)^*days$, where Ta is the daily mean near-surface air temperature, $Tac = 65^{\circ}\text{F}$ (18°C) is an average daily-mean temperature threshold for human thermal comfort, and $days$ is the number of days with temperatures exceeding Tac . Intensity is simply the difference between Ta and Tac , but it can be further broken down into daytime (maximum) and nighttime (minimum) temperature intensities. Humidity also plays a role in the human thermal comfort threshold; however, California is very dry during the summer, and therefore humidity is not a significant factor for this region.

This study's analysis of changes in extreme heat implicitly accounted for technology and population change through atmosphere-ocean general circulation model (AOGCM) projections forced by the Intergovernmental Panel on Climate Change (IPCC) Special Report on Emission Scenarios (SRES) (Nakicenovic et al. 2000). The SRES scenarios include a range of population increases and accompanying technological and societal changes. However, in the calculation of California's regional energy demand, technology and population were held constant at today's levels in order to quantify the range of possible outcomes as a perturbation about the historical demand. This perturbation approach has been used in previous impact assessment studies (e.g., USGCRP 2000). It provides a constrained estimate of potential outcomes that can be extrapolated using a range of projected changes in population and technology applied to demand. Here, the possibility of such extrapolated scenarios are briefly explored, although technological advancement is difficult, if not impossible, to project beyond about a 10-year timeline, because of the large uncertainties pertaining to the rate of discovery, evaluation, and social adaptation of new technologies.

Similar to previous assessments of temperature and extreme heat increases for California (e.g., Hayhoe et al. 2004; Cayan et al. 2006), three AOGCMs were used: the U.S. Department of Energy/National Center for Atmospheric Research (DOE/NCAR) Parallel Climate Model (PCM) (Washington et al. 2000); the National Oceanic and Atmospheric Administration/ Geophysical Fluid Dynamics Laboratory (NOAA/GFDL) CM2.1 (Delworth et al. 2006); and United Kingdom Meteorological Office (UKMO) HadCM3 (Pope et al. 2000) model.

As illustrated by Figure 1, use of three AOGCMs captures the greater part of the scientific uncertainty inherent in future projections of temperature increases in response to human emissions. The PCM model lies at the lower end, whereas GFDL and HadCM3 fall at the mid to higher end of the full IPCC range of 2°C to 4.5°C for a doubling of atmospheric CO_2 concentrations (Alley et al. 2007).




Figure 1. Projected average summer (JJAS) temperature increases for California under the SRES higher (A1fi), mid-high (A2), and lower (B1) emissions scenarios, as simulated by the HadCM3, GFDL CM2.1, and PCM models. Temperature changes are larger under the higher emission scenarios as compared to the lower, and for the higher sensitivity models (HadCM3 and GFDL CM2.1) as compared to the lower sensitivity model (PCM).

As also illustrated in Figure 1, even greater uncertainty is introduced by assumptions regarding future emissions from human activities. For that reason, the three AOGCMs are forced by three different emission scenarios for the period 2000 to 2099: the IPCC SRES higher (A1fi; fossil intensive, with rapid technological and economic growth), mid-high (A2; a heterogeneous world, with regionally oriented development and slower growth), and lower (B1; a convergent world that transitions rapidly to an information-based, rather than material-based, economy) scenarios. These IPCC SRES scenarios represent the range of non-intervention emissions futures, with projected 2100 atmospheric CO₂ concentrations reaching approximately 550 parts per million (ppm) to almost 1000 ppm.

For each of the nine model/scenario combinations used here (GFDL A1fi simulations were not available at the time of the analysis), projected California-wide temperature increases were first calculated directly from the AOGCM output (Figure 1). This coarse-resolution approach tends to cause a slight cool bias, due to the proportion of grid cells near ocean waters and mountainous regions. For that reason, AOGCM-based maximum and minimum daily

temperatures were then statistically downscaled to the individual city level using historical model simulations and the long-term observational weather station records. Downscaled daily temperature time-series were generated for five urban centers within California; San Francisco, Los Angeles, Sacramento, Fresno, and San Bernardino/Riverside.

Statistical downscaling was accomplished using multiple linear regression equations based on the nearest long-term daily weather station observations for each city. Statistical downscaling procedures have the advantage of being computationally efficient, but as they rely on historical relationships between large-scale climate fields and local variables, partial stationarity over time must be assumed. Statistical downscaling through regression is a common approach that has been well-documented in the literature (Wilby et al. 1998; Huth et al. 2002; Wilby et al. 2002; Wilby and Dawson 2004), with the method used here being described in Dettinger et al. (2004).

Specifically, observed temperatures for 1976 to 1990 were used to train a set of linear third-order regression equations that transform the large-scale temperature predictors to a local-scale predictand, while preserving the distribution of the observed mean and variance. The resulting model was then verified on the 1961–1975 period with the downscaled time-series having a near-exact fit to observations. Future projections were then averaged for three time periods (2005–2034, 2035–2064, and 2070–2099) to produce climatological near-term, mid-term, and long-term projections of increased temperatures for California on which to base estimates of future shifts in the timing and magnitude of electricity demand.

3.0 Results

To determine the likely impacts of climate change under higher and lower emissions scenarios, researchers calculated projected increases in average daily temperature, the number of future days that would exceed the historical T90 threshold, and the average JJAS CDD values. These projections were then used as the basis for determining changes in statewide and urban demand for electricity for cooling under assumptions of present-day population and technology. Lastly, the impacts of upper and lower-bound population growth and technology advances in California were extrapolated to estimate the likely future range of peak electricity demand and also evaluate the potential to mitigate the impact of temperature on electricity shortages through adaptation.

3.1. Projected Increases in T90 Events

During the historical period (1961–1990), by definition T90 events occurred an average of just over 12 times per year, 12 being equal to 10% of the total number of days in the months of June through September. Using the T90 threshold defined by the historical 90th percentile temperature threshold (see Table 1 for historical T90 threshold temperatures for each city), the number of days projected to exceed this threshold in the future were then evaluated, both at the state level and for the five urban centers examined here.

As average temperatures rise, the historical T90 threshold will be exceeded more frequently. Moreover, T90 events are expected to be more intense (i.e., hotter), last longer, and occur earlier in the season relative to the 1961–1990 reference period.

For California as a whole, the total number of T90 days is projected to *double* relative to a historical mean of 12 days per summer, to an average of 23–24 days per summer as early as 2005–2034. By mid-century (2035–2064), this becomes 27–39 days (B1), 29–47 days (A2), and 32–54 days (A1fi). By the end of the century (2070–2099), the statewide number of JJAS T90 days are projected to increase an average of four times (B1), 5.5 times (A2), and 6.5 times (A1fi) relative to the historical average (Table 1 and Figure 2).




Figure 2. California-wide projected average number of JJAS T90 days per year from 1975 to 2100. Year-to-year variations have been smoothed using a 10-year running mean to show long-term trends. Projected values are shown for the HadCM3, GFDL CM2.1, and PCM models. Shaded arrows indicate the end-of-century range for simulations corresponding to the SRES A1fi (higher, red/orange), A2 (mid-high, blue), and B1 (lower, green) emission scenarios.

As shown in Table 1, T90 threshold values for the urban locations vary from a low of 27°C for San Francisco up to 40°C for Fresno. Using city-specific T90 thresholds, similar increases in the number of JJAS T90 days were projected for the five urban locations (Table 1). By 2005–2034, in most cities the number of days doubles relative to the historic reference period. By the end of the century, there are projected to be 3.5 to 4 times more T90 days under B1, 5.5 to 6 times more days under A2, and 6 to 7 times more days under the higher A1fi scenario.

As for the statewide projections, increases for individual urban areas are proportionally larger under the higher emissions scenarios (A1fi and A2), relative to the lower B1. Furthermore, coastal cities such as Los Angeles and San Francisco are projected to see changes of more than 90 T90 days by the end-of-century under the A1fi and A2 scenarios, as compared with slightly lower projections of 70 to 80 T90 days per year for inland areas.

Table 1. T90 threshold values (in degrees Celsius, determined such that an average of 12 days per year exceed the T90 threshold during the period 1961–1990), and projected increased number of days exceeding the 1961–1990 T90 threshold for near-term (2005–2034), mid-century (2035–2064), and end-of-century (2070–2099) periods. Values shown are the range given by HadCM3, GFDL CM2.1, and PCM model simulations for the SRES A1fi (higher), A2 (mid-high), and B1 (lower) emissions scenarios.

	T90 threshold (°C)	Scenario	No. of days exceeding T90 threshold		
	1961–1990		2005–2034	2035–2064	2070–2099
Statewide	35	A1fi	19–34	32–66	69–88
		A2	18–30	29–47	53–76
		B1	21–26	27–39	39–52
San Francisco	27	A1fi	20	32–46	70–94
		A2	13–28	20–48	40–91
		B1	17–23	23–35	37–49
Los Angeles	33	A1fi	24	34–50	63–93
		A2	16–24	23–48	39–98
		B1	19–24	27–36	38–45
Sacramento	38	A1fi	20	33–46	70–78
		A2	15–36	25–49	47–89
		B1	17–23	26–42	40–52
San Bernardino	40	A1fi	21–23	31–46	63–78
		A2	13–27	20–46	36–87
		B1	20–27	26–36	36–45
Fresno	40	A1fi	19–21	33–45	69–75
		A2	15–35	25–51	46–93
		B1	16–27	26–42	40–52

3.2. Projected Increases in CDD Values

Statewide, annual CDD values for a 18°C (65°F) mean temperature threshold average 400°C-days to 500°C-days per year for the period 1961–1990. For California as a whole, average CDD values are projected to increase to 600°C-days–1000°C-days by mid-century. By end-of-century, the difference between emissions scenarios becomes clear, with CDD values for California ranging from 650°C-days–1000°C-days under the lower B1 scenario, and up to 800°C-days–1250°C-days and 1000°C-days–1500°C-days under the higher A2 and A1fi scenarios, respectively. These increases are double (B1) to triple (A2, A1fi) the historical values.

Perhaps even more relevant to electricity supply is the average CDD value during a T90 event, when the electric power demand peaks. California currently has a CDD value of approximately 20°C-days per day during summer heat episodes. For each degree above the base comfort per day (°C-days), an additional amount of energy will be required for cooling.

By mid-century, daily CDD values for T90 days are projected to increase from their present-day value of 20°C-days up to approximately 100°C-days. By the end of the century, daily CDD values during T90 events exceed 150°C-days under most scenarios (Figure 3). Together, the impact of projected increases in T90 day frequencies and duration (with more such events occurring closer together or even consecutively) act to enhance daily average CDD values as well as JJAS totals, likely increasing peak electricity demand.




Figure 3. California-wide duration and intensity for JJAS T90 events from 1960 to 2100 as simulated by the HadCM3, GFDL and PCM models for the SRES A1fi (higher), A2 (mid-high), and B1 (lower) emission scenarios, as labeled. Note that GFDL A1fi simulations were not available at the time of calculation.

At the urban scale, similar increases in CDD values are seen for the five cities examined here (Table 2). Resolving individual urban centers also shows that there are significant inland and coastal differences in the T90 values and the corresponding CDD values, with projected

increases being greatest in the southern and inland locations. Additional projected CDD increases for cities further north and south (Crescent City and El Centro, not shown) confirm this north-south gradient of increasing T90 and CDD values.

Also in contrast to the T90 analysis, interscenario differences are more evident before the mid-century, with projected increases for 2035–2064 ranging from 50°C-days per year up to 80°C-days per year under B1 and up to 150°C-days per year under A1fi for the more northerly San Francisco. As the CDD values increase towards the end of the century, even greater increases are seen under the higher A1fi and A2 emission scenarios relative to the lower B1 emission scenario (Table 2). By the end of the century, the projected increase in CDD values under the A2 and A1fi scenarios range from 150°C-days per year in the north, up to 750°C-days per year in the south, and are 1.2 to 2.3 times greater than that projected under B1.

Table 2. Historical (1961-1990) simulated and projected future change in annual Cooling Degree Days (CDD) relative to the historical average for five California cities, listed from low to high present-day CDD values. Values shown for the SRES A1fi (higher), A2 (mid-high), and B1 (lower) emission scenarios for the range simulated by downscaled projections from the HadCM3, GFDL2.1, and PCM models.

	1961-1990 (absolute value)	2035-2065			2070-2099		
		A1fi	A2	B1	A1fi	A2	B1
San Francisco	60	+ 90-150	+ 90-100	+ 60-90	+ 260-340	+ 140-220	+ 110-150
Los Angeles	570	+ 190-340	+ 210-310	+ 150-200	+ 410-590	+ 260-550	+ 230-310
Sacramento	690	+ 310-400	+ 270-360	+ 220-280	+ 630-720	+ 310-630	+ 330-410
San Bernardino/Riverside	800	+ 250-430	+ 200-410	+ 190-270	+ 520-750	+ 240-750	+ 290-390
Fresno	900	+ 320-410	+ 200-370	+ 220-310	+ 640-730	+ 250-670	+ 340-410

3.3. Projected Increase in Electricity Demand

Peak electricity demand and temperatures in California are strongly correlated. For temperatures above 28°C (82°F), California peak electricity demand exhibits a linear increase at a rate of 700 MW/°F (DOE 2004; CEC 2002). In 2004, the 1-in-10 (T90) California JJAS peak electricity demand outlook was 57 GW, indicating a remaining reserve margin of only 5.5% and a Stage I electricity emergency. At electricity demand levels above 57 GW, spot markets are used. For statewide mean daily temperatures above 86°F (30°C), electricity demand exceeds 60 GW, and capacity is less than 5%, resulting in Stage II electricity emergency response programs being put into effect. When only 3% of the reserve margin is available, a Stage III emergency alert is proclaimed, accompanied by rolling blackouts.

Using the above temperature-demand relationship, statewide JJAS peak electricity demand increases under all projections of future climate change, due to the increased frequency of days warmer than 28°C (82°F). Residential peak electricity demand at mid-century is projected to increase by 2.8%–10.0% under the A1fi and A2 scenarios and by 3.4%–7.7% under the B1 scenario. By the end-of-century, this demand will increase by 6.2%–19.2% under the A1fi and

A2 scenarios, and by 4.0%–11.2% under the B1 scenario. Much of this increased peak demand is projected to occur simultaneously across the state, as extreme heat events are of a regional rather than local nature. This raises concerns regarding the reliability and structural stability of the energy grid to supply the needs of all sectors, including industrial, residential, and emergency services.

This demand analysis holds the Gross Daily Product (GDP) and aggregate population constant at today's level, to illustrate the effect of the increased frequency of extreme heat days on peak electricity demand. Based on this approach, the increases in aggregate demand come from temperature-induced increases in the per capita rate of electricity consumption. The CEC (2005) forecasts reflect a growth of aggregate peak electricity demand essentially matching population growth. This implies that improvements in "electricity efficiency" of the economy have to exactly offset the increased demand.

Of course, it is not only the increased frequency of extreme heat days that drives up peak demand. Economic growth of California's economy measured by increasing the gross state product is another main determinant of electricity demand. Although historically per capita energy consumption has been flat, due to aggressive energy efficiency programs, technological advances will have to offset increases from both of these factors to grow electricity supply at the same rate as population growth.

4.0 Discussion

Projected increases in extreme temperatures characterized by a T90 threshold, cooling degree days, and direct estimates of electricity demand all suggest that electricity demand in California is likely to continue to rise over this century. Although California's installed electricity capacity will also continue to grow over time, its current rates of growth suggest frequent summer electricity shortages may occur as early as 2020. This scenario is particularly more likely for southern California, where the electricity operating reserve has already dropped below the 5% reserve margin during multiple hot days in recent years. By the end of this century, all model/scenario combinations indicate an increase in region-wide extreme temperature conditions of a severity associated with electricity shortages under the current configuration of the electric power system and patterns of demand.

Furthermore, population estimates suggest a large influx along major transportation corridors in the California Central Valley, a region that is already very hot during JJAS, requiring air conditioner use. If a doubling and a quadrupling of the population within the Central Valley were imposed during this century, then the demand side would also increase proportionally and supply would consequently need to be doubled or quadrupled as well. As mentioned earlier, technological advancement is highly unpredictable; however, there is always the possibility of breakthroughs.

The natural conclusion arising from projections such as these is that electricity production must be significantly increased. However, in future years, meeting California's demand for electricity—including peak power—will most likely require a combination of new supplies, improved transmission and distribution facilities, and further enhancement of the demand-side policies and programs that are already in place. In particular, adaptation to future change through widespread adoption of conservation and passive cooling strategies may have the potential to reduce the projected increase in future electricity demand significantly. By raising the average temperature threshold at which air conditioning is commonly turned on through adaptation strategies such as the use of fans and flow-through ventilation, less electricity would be required for cooling under a given temperature regime. This is not unheard-of in California; during the 2000–2001 energy crises, Californians responded to an imposed electricity efficiency and demand program that resulted in a reduction of approximately 6000 MW, representing 10% of the peak demand (CEC 2004). During the summer of 2000, there were 29 days where electricity demand exceeded 40,000 MW. Although the summer of 2001 was as hot as 2000, there was a substantial reduction in demand, with only six such days occurring. This reduction was due to a combination of price increases and voluntary reduction of electricity use.

Some measure of the adaptive potential for reducing projected increases in CDD and the subsequent rise in residential and commercial electricity demand can be obtained through comparing projected increases in CDD values calculated based on the standard 65°F (18°C) threshold with CDD values calculated using a higher threshold of 75°F (24°C). Raising the CDD threshold by 10°F through more efficient cooling with fans and ventilation would greatly reduce the projected increase in CDD values and related electricity demand, particularly for coastal cities (Figure 4). This simplified assumption suggests potential savings through adaptation. For

San Francisco, raising the CDD threshold to 75°F would result in end-of-century CDD increases of less than 15°C-day per year, effectively eliminating any increases in projected demand under both the A1fi/A2 and B1 scenarios. Los Angeles shows potential reductions of 40%–55% in projected CDD increases relative to the 65°F threshold, while inland cities (San Bernardino, Sacramento, Fresno) indicate an adaptive capacity ranging from 10%–40%.

Considering that significantly higher CDD values and related electricity demand result from higher (as compared with lower) emission scenarios, and that most affordable near-term options for increasing electricity supply via fossil fuels also involve simultaneous increases in GHG emissions, these estimates of adaptation potential have important implications for decision making at the city and state level.




Figure 4. Projected increase in annual CDD for a 65°F (solid) vs. a 75°F (lined) average temperature threshold for 2070–2099, relative to 1961–1990. Results shown are the averaged projections from the HadCM3, GFDL2.1, and PCM models for the SRES A2 (mid-high, orange) and B1 (lower, yellow) emission scenarios for five California cities. Comparison of the projected change based on a higher vs. a lower threshold value for CDD calculation illustrates the adaptation potential for mitigating projected future energy demand, which appears to be greater for coastal cities (San Francisco, Los Angeles) and less for inland areas (Sacramento, Fresno, San Bernardino).

5.0 Summary and Conclusions

All indicators point to increases in summer electricity demand in California, even when confounding factors such as increased population and market saturation of air conditioning are disregarded. Through calculation of projected increases in extreme heat and electricity demand, the difference in potential impacts resulting from lower and higher emissions scenarios can be quantified. Model uncertainties notwithstanding, extreme heat and associated human health risks and electricity demands under the B1 lower emissions scenario are significantly lower than those projected to occur under the A2 and A1fi higher scenarios. Calculations of electricity demand under a range of human comfort levels also highlight the potential for adaptation to play a major role, reducing projected increases in electricity demand by roughly one third for inland cities, and by as much as 95% for cooler coastal cities.

Alternative technologies such as solar photovoltaic electricity generation represent an important future technology for this region, with electricity production being proportional to solar radiation and thus closely matching summer peak electricity demand (Borenstein 2005). Technologies such as these have the potential to reduce the cost associated with increased demand for cooling under a warmer climate without increasing emissions of GHGs that are causing the problem in the first place.

In conclusion, the influence of climate change on extreme heat and electricity demand in California and other similar air-conditioned regions is likely to challenge current-day providers, spur conservation and adaptation measures, and raise questions regarding the potential for mitigation to reduce projected increases through following a lower emissions pathway worldwide.

6.0 References

- Alley, R. et al. 2007. *Climate Change 2007: The Physical Science Basis: Summary for Policymakers*. Contribution of Working Group I to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change. Cambridge University Press, 21pp. Available online at: www.ipcc.ch/SPM2feb07.pdf.
- Amato, A., M. Ruth, P. Kirshen, and J. Horwitz. 2005. "Regional energy demand responses to climate change: Methodology and application to the Commonwealth of Massachusetts." *Climatic Change* 71: 175–201.
- Batholomew, E. S., R. Van Buskirk, and C. Marnay. 2002. *Conservation in California during the summer of 2001*. LBNL-51477, 22 pp.
- Belzer, D., M. Scott, and R. Sands. 1996. "Climate Change Impacts on U.S. Commercial Building Consumption: An Analysis Using Sample Survey Data." *Energy Sources* 18: 2.
- Borenstein, S. 2005. Valuing the Time-Varying Electricity Production of Solar Photovoltaic Cells. University of California Energy Institute Working Paper 142 (CSEM WP-142).
- California Energy Commission (CEC). 2002. 2002–2012 *Electricity Outlook Report*. P700-01-004F, 174 pp.
- California Energy Commission (CEC). 2004. *Integrated Energy Policy Report*. California Energy Commission Report 100-04-006CM, 80 pp.
- California Energy Commission (CEC). 2005. *Summer 2005 Electricity Supply and Demand Outlook*. California Energy Commission Report CEC-700-2005-006-SD.
- Cartalis, C., A. Synodinou, M. Proedrou, A. Tsangrassoulis, and M. Santamouris. 2001. "Modifications in energy demand in urban areas as a result of climate changes: An assessment for the southeast Mediterranean region." *Energy Conv and Mgmt*. 42: 1647–1656.
- Cayan, D., A. L. Luers, M. Hanemann, G. Franco, and B. Croes. 2006. *Possible scenarios of climate change in California: Summary and recommendations*. CEC-2005-186-SD.
- Colombo, A. F., D. Etkin, and B. W. Karney. 1999. "Climatic variability and the frequency of extreme temperature events for nine sites across Canada." *J. Climate* 12: 2490–2502.
- Delworth, T. L., A. J. Broccoli, A. Rosati, R. J. Stouffer, et al. 2006. "GFDL's CM2 global coupled climate models – Part 1 – Formulation and simulation characteristics." *J. Climate* 19: 643–674.
- Dettinger, M. D., D. R. Cayan, M. K. Meyer, and A. E. Jeton. 2004. "Simulated hydrologic responses to climatic change variations and change in the Merced, Carson, and American River Basin, California 1900–2099." *Climatic Change* 62: 283–317.
- Department of Energy (DOE). 2004. Technical Support Document: Energy efficiency program for commercial and industrial equipment: Commercial unitary air conditioners and heat pumps.

Government Accountability Office (GAO). 2005. *Meeting energy demand in the 21st century*. GAO-05-414T, 34 pp. www.gao.gov.

Hayhoe, K., D. Cayan, C. B. Field, P. C. Frumhoff , E. P. Maurer, N. L. Miller, S. C. Moser, S. H. Schneider, K. Nicholas Cahill, E. E. Cleland, L. Dale, R. Drapek, R. M. Hanemann, L. S. Kalkstein, J. Lenihan, C. K. Lynch, R. P. Neilson, S. C. Sheridan, and J. H. Verville. 2004. "Emissions pathways, climate change, and impacts on California." *Proc. Natl. Acad. Sci.* 101: 12422–12427.

Henley, A., and J. Peirson. 1998. "Residential energy demand and the interaction of price and temperature: British experimental evidence." *Energy Economics* 20: 157–171.

Huth, R. 1999. "Statistical downscaling in central Europe: Evaluation of methods and potential predictors." *Climate Res.* 13: 91–101.

Mendelsohn, R., and J. Neumann. 1999. *The Impact of Climate Change on the United States Economy*. Cambridge University Press, Cambridge, UK.

Miller, N. L., and K. Hayhoe. 2006. Emissions scenario-based analysis of projected extreme heat and energy costs in California, Forum on Risks and Impacts on Society, 86th Annual AMS Meeting, 29 January–2 February 2006, Atlanta, Georgia.

Nakicenovic', N., J. Alcamo, G. Davis, B. de Vries, J. Fenner, S. Gaffin, K. Gregory, A. Grubler, T. Y. Jung, T. Kram, et al. 2000. *Intergovernmental Panel on Climate Change Special Report on Emissions Scenarios*. Cambridge University Press, Cambridge, U.K.

NOAA. 2006. July 2006 Statewide Temperature Ranks, National Climate Data Center, NESDIS www.noaanews.gov/stories2006/s2677.htm.

Owenby, J., R. Heim, M. Burgin, and D. Ezell. 2005. Climatology of the U.S. No. 81 - Supplement # 3, Maps of Annual 1961–1990 Normal Temperature, Precipitation and Degree Days, Online Document Library, www.ncdc.noaa.gov/oa/documentlibrary/clim81supp3/clim81.html.

Pope, V. D., M. Gallani, P. Rowntree, and R. Stratton. 2000. "The impact of new physical parametrizations in the Hadley Centre climate model: HadAM3." *Climate Dynamics* 16: 123–146.

Rosenthal, D., and H. Gruenspecht. 1995. "Effects of global warming on energy use for space heating and cooling in the United States." *Energy Journal* 16: 2: 77–96.

Tebaldi, C., K. Hayhoe, J. Arblaster, and J. Meehl. 2006. "Going to the extremes: An intercomparison of model-simulated historical and future changes in extreme events." *Climatic Change* 10.1007/s10584-006-9051-4.

USGCRP. 2000. *Climate change impacts on the United States: The potential consequences of climate variability and change*. Editors: Melilo, J. M., A. C. Jaccard, T. R. Karl, and the National Assessment Synthesis Team. 2000: U.S. Global Research Program, U.S. Climate Change Research Program, Washington, D.C.

- Valor, E., V. Meneu, and V. Caselles. 2001. "Daily air temperature and electricity load in Spain." *J. Appl. Met.* 40: 1413–1421.
- Wilby, R. L., and C. W. Dawson. 2004. *Using the Statistical DownScaling Model (SDSM) Version 3.1 – A decision support tool for the assessment of regional climate change impacts. User's Manual.* Climate Change Unit, Environment Agency of England and Wales, 67 pp.
- Wilby, R. L., C. W. Dawson, and E. M. Barrow. 2002. "SDSM - a decision support tool for the assessment of regional climate change impacts." *Environmental Modelling and Software* 17(2): 145–157.
- Wilby, R. L., T. M. L. Wigley, D. Conway, P. D. Jones, B. C. Hewitson, J. Main, and D. S. Wilks. 1998. "Statistical downscaling of general circulation output: A comparison of methods." *Water Resources Res.* 34: 2995–3008.
- Washington, W. M., J. W. Weatherly, G. A Meehl, A. J. Semtner, T. W. Bettge, A. P. Craig, W. G. Strand, J. Arblaster, V. B. Wayland, R. James, and Y. Zhang. 2000. "Parallel climate model (PCM) control and 1% per year CO₂ simulations with a 2/3 degree ocean model and 27 km dynamical sea ice model." *Climate Dynamics* 16: 755–774.